

# 'Busy' Record, Put-callback Lab

Kay Kasemir

Jan. 2019

ORNL is managed by UT-Battelle, LLC for the US Department of Energy

# Adding Busy Record to IOC

Busy record is not included in EPICS base.

Add to IOC via `SomeApp/src/Makefile`

```
Some_DBD += busySupport.dbd  
Some_LIBS += busy
```

See `examples/CombinedApp`

# Example Database

- Read `examples/CombinedApp/Db/busy_demo.db`
- Start `examples/iocBoot/iocCombined/st.cmd`
- Monitor `DemoDevice` and `DemoDeviceReadback`, for example using the display in `CombinedApp/opi`
- Try the following, explain what's happening

```
caput DemoDevice 2
```

```
caput DemoDevice 5
```

```
caput -c -w 20 DemoDevice 2
```

```
caput -c -w 20 DemoDevice 5
```

```
caput -c DemoDevice 2
```